



## Features

- Any combination of MIX-4000 series devices up to 240 can be connected on a single SLC.
- Mounts in a standard 4" square or double gang electrical back box.
- Indicating LED provides module status.
- Compatible with conventional two wire or 4-20mA devices.
- Can be configured for one (1) Class A or one (1) Class B circuit with conventional devices

## Benefits

- A single stocked device type covers two applications:
  - Conventional Zone Input Module
  - 4-20mA two-wire devices
- Compatible with a large array of two-wire devices. See Mircom document LT-1023.

## Description

The MIX-4042 Analog interface module is designed to be used with an MGC compatible control panel providing high rates of information exchange and fast and secure responses.

The MIX-4042 Conventional Zone Module allows a zone of conventional two-wire detectors to be interfaced to an intelligent loop. It can also be configured to work with 4-20mA devices.

An external listed power supply can be connected to several MIX- 4042 modules to provide power to the devices while remaining electrically isolated from the FACP.

Each MIX-4042 monitors the current used by the devices and reports alarms and troubles accordingly.

When configured for conventional devices, the module will automatically handle Class A or Class B lines.

The MIX-4042 has an internal EOL resistor for Class A lines. An MP-300 end of line resistor must be used for Class B wiring.

The module has a panel controlled LED indicator. The LED flashes during normal operation and stays ON steadily when the device is in alarm condition.

The MIX-4042 supports 2-wire smoke detectors on a Class A/B loop, or alternatively, the MIX-4042 can be configured to support 4-20mA devices. Trouble and monitor event current threshold can be set at configuration time. Due to UL listing requirements, alarm compatibility with 4-20mA devices will be determined on demand.

The address of each module is set using the MIX-4090 programmer tool. For setting the address on this device, disconnect it from the loop, or ensure that the loop to which is connected is both disconnected from the panel and shorted across the SCL+ and SLC- inputs at the device. Failing to take either of these steps may change the address programming of previously configured sensors on the loop.



## Technical Specifications

SLC Specs	
Normal Operating Value	15 to 30 VDC
Standby Current	1.6mA
Alarm Current	3.0mA
Devices Specs	
EOI Resistance (Conventional Zone)	3900 Ohms
Max Wiring Resistance (4-20mA)	200 Ohms
Max Wiring Resistance (Conventional Zone)	100 Ohms
External Power Supply	24VDC nominal (18 to 30 V)
External Supply Current	23mA maximum at 30 VDC (E.O.L. only)
EOL Current (Conventional Only)	5mA maximum
Conventional Devices Current	3mA total or less
Max Short Circuit Current	70mA(55mA on devices line)
Temperature Range	32°F to 120°F (0°C to 49°C)
Humidity	10% to 93% Non-condensing
Wiring Range on all terminals	22 to 12 AWG
Dimensions	4.625"H x 4.25" W x 1.125" D
Mounting	Typically mounted on a standard 4" square box. Also compatible with double-gang electrical boxes or Mircom BB-400 surface mount box.

\* See Mircom document LT-1023 for compatible two wire devices

## Ordering Information

Model	Description
MIX-4042	Conventional Zone Module
MIX-4090	MIX-4000 Addressable Device Programmer
MP-302	EOL on mounting plate
BB-400	Surface Mount Electrical Box



**Canada**  
 25 Interchange Way  
 Vaughan, Ontario L4K 5W3  
 Telephone: (905) 660-4655  
 Fax: (905) 660-4113

**U.S.A.**  
 4575 Witmer Industrial Estates  
 Niagara Falls, NY 14305  
 Toll Free: (888) 660-4655  
 Fax Toll Free: (888) 660-4113



**THIS INFORMATION IS FOR MARKETING PURPOSES ONLY AND NOT INTENDED TO DESCRIBE THE PRODUCTS TECHNICALLY.**

For complete and accurate technical information relating to performance, installation, testing and certification, refer to technical literature. This document contains intellectual property of Mircom. The information is subject to change by Mircom without notice. Mircom does not represent or warrant correctness or completeness.