

1 Mount the Enclosure

The enclosure mounts on the wall. Mount the enclosure right-side up (the Mircom logo on the door is in the lower right corner).

You need:


- 4 fasteners appropriate for the wall that you are mounting the enclosure on.
1. Find a suitable location for the enclosure.
2. Mark the back mounting locations of the two top screws. Ensure that at least one screw is over a wall stud.
3. Place the fasteners halfway into the wall in the two top keyhole locations and wall stud.
4. Place the enclosure onto the fasteners, then lower it so that the fasteners fit in the narrow part of the keyholes.
5. Screw the other fasteners into the remaining holes.
6. Tighten all fasteners into place.

To prevent water from entering the unit, use a weather resistant conduit hub. Mircom recommends using the TX3-TOUCH-WR-BB backbox for mounting Outdoor Touch Screens when the wall does not have in-wall wiring or is uneven. Please refer to LT-6192 and LT-996 for installation instructions.

Installation Prerequisites

- Verify that the building telephone infrastructure is operational. When wiring an NSL installation it may be necessary to check each resident's line.
- Ensure there is a provision for a ground circuit. The Telephone Access System assembly must be grounded by a qualified electrician. An improperly grounded unit can result in equipment malfunction and void the warranty.
- Use the latest Telephone Access System controller firmware. Mircom periodically updates panel firmware and Configurator Software to add features and correct any minor inconsistencies. For information about the latest firmware or software visit the 'Manuals and Downloads' section of the Mircom website at www.mircom.com

AC or DC Door Strikes: see 2 and 3
Auxiliary Door Strike: see 4



Warning: Turn the power off before wiring

Install all power supplies outside the enclosure.

Wiring Requirements

Unless specified otherwise, all wiring is a maximum length of 1000 ft (304.8 m).


RS-485: Maximum total length: 4000 ft (1219.2 m)
Use twisted shielded pair.

Door Strike: The door strike power supply depends on the door strike power requirements.


Maximum Power Supply Wire Distances

Gauge	Distance
16	125 ft (38.1 m)
14	200 ft (60.96 m)
12	320 ft (97.536 m)
10	500 ft (152.4 m)


2 AC Door Strike or Maglock 18 AWG




4 Auxiliary Door (Output 2) 18 AWG



Outputs 2-4




3 DC Door Strike (Output 1) 18 AWG




The maximum supply for the AC or DC Power Supply for Door Strike must not exceed:

28 VAC / 1 A max
30 VDC / 1 A max

Alternative Wiring for Dry Contact



5 DIP Switch Settings for RS-485 Address



Each Touch Screen must have a unique RS-485 address.

Use DIP switches 1-6 to set the RS-485 network address. See LT-969 for details. Leave DIP switch 7 on.

Mircom
<http://www.mircom.com>
CANADA - Main Office
25 Interchange Way
Vaughan, ON L4K 5W3
Tel: (888) 660-4655
(905) 660-4655


U.S.A
4575 Witmer Industrial Estates
Niagara Falls, NY 14305
Tel: (888) 660-4655
TECHNICAL SUPPORT
Tel: 1-888-647-2665

For more details, see LT-996 and LT-969 on the Mircom website and the USB flash.
Mircom technical support: 1-888-647-2665


TX3-TOUCH-S15B-WR and TX3-TOUCH-S15S-WR QUICK START



Warning: Turn the power off before wiring.




6 Postal Lock (Input 1)
Fire Alarm Override (Input 2)
Door Contact (Input 3)
22 AWG




For more details, see LT-996 and LT-969 on the Mircom website and the USB flash.
Mircom technical support: 1-888-647-2665

7 Phone Lines




8 Camera Supply
Note: Do not use for any other purpose




Activation of this input relocks the main door (Output 1).
Activation of this input unlocks the main and auxiliary doors (Outputs 1 and 2).


9 RS-485



10 Ground and Power



11 Mount the TX3-PS24-5A
24 VDC, 156 W
Power Supply



Attention: Install the power supply indoors, and outside the Touch Screen enclosure.
To surface mount the power supply enclosure: You need 4 fasteners appropriate for the wall that you are mounting the enclosure on.


1. Find a suitable location for the power supply enclosure, such as over a wall stud.
2. Using the enclosure as a template, mark the two top mounting hole locations. Ensure that at least one side is over a wall stud.
3. Remove the enclosure and place two wall fasteners halfway into the marked hole locations.
4. Place the enclosure onto the fasteners and lower it so that the fasteners fit in the narrow part of the keyholes.
5. Screw the other two fasteners into the two remaining holes.
6. Tighten all four fasteners into place.

Note: The enclosure can also be mounted directly onto the drywall using anchors.

WARNING
To ensure the security of occupants, change the level 3 passcode from its default setting. See LT-995 on mircom.com for details.

12 Connect the Power

1. Set the voltage selectable switch on the power supply to the appropriate voltage. The voltage selectable switch can be set to either 115 V or 230 V.
2. Connect the load power supply wires to the Touch Screen terminal screws as shown in step 10.
3. Connect the other end of the load power supply wires to the **Load** terminals.
4. Connect the building power supply wires to the **Line** terminals as shown below.
5. Turn the power on by pressing the power button.



13 Connect the UPS

Note: If the Touch Screen has Windows 10, then the UPS is not required. Touch Screens with Windows 10 have an SO-440/ SO-441/ SO-411 sticker with the version 2.15.7 or higher on the PC board.

Follow the manufacturer's instructions included with TX3-TOUCH-UPS-KIT, and see the Mircom document LT-6714, included with TX3-TOUCH-UPS-KIT.