

## **Replacement or Upgrade CFast Card** Installation Instructions

These instructions explain how to upgrade TX3 Touch 15 inch models to Windows 10 or replace the Windows 10 CFast Card in TX3 Touch 15 inch models.

There are 2 kits, depending on the model:

RPL-TX3-CF32W10-15D: For replacing or upgrading the 32 GB CFast card in TX3-TOUCH-S15-D and TX3-TOUCH-F15-D

RPL-TX3-CF32W10-15WR: For replacing or upgrading the 32 GB CFast card in TX3-TOUCH-S15B-WR and TX3-TOUCH-S15S-WR

You need:

- USB flash drive
- USB mouse

## A. Back up the Job to the USB Flash Drive

**Note:** You do not need to back up or restore the job if you use the Configurator to send the job to the Touch using IP.

1. Insert the USB flash drive into the USB port.



2. From the main touch screen display enter 9999.

The administrator access code window appears.

- Enter the password to log in to the system and press OK (by default the there is no password).
- 4. Select File Backup from the Menu Bar. The Backup Jobs window appears.



Backup Jobs			×
Backup all jobs		in tr	nclude event logs
Backup current	job only		
Folder to store back	up files		
F:\			Browse
(	Backup Now	Close	h

- 5. Select Backup current job only.
- 6. Click Browse and choose the USB flash drive as the location to store the backup files.
- 7. Click Backup Now.
- 8. Select File Shut Down Shut Down from the Menu Bar.
- 9. Click Yes to confirm.
- 10. If the Touch Screen has an on/off toggle switch, turn it off.
- 11. Disconnect the power to the Touch Screen.

## B. Replace the CFast Card

The CFast card is on the left side of the PC board, which is in the top left corner of the inner chassis.

1. Press the release lever to eject the CFast card.



**Release lever on -D models** 



2. Insert the new card into the slot.

Slide the card into the slot with the logo up as shown below.



CFast Card in RPL-TX3-CF32W7-22D

The card should slide in easily and rest in the same location as the old card. Forcing the card can damage the equipment.

3. Start the Touch Screen.

## C. Turn on the Unified Write Filter (UWF)

1. Enter 9999 on the TX3 Touch screen.





2. Touch OK.

File	Edit Panels	Reports	Tools	Help				
	New Job	1	20	,	0		<b>≙</b> ₹	->
1	Open Job	qu	Add R	es	Add Card	s Disc	onnect	Send
	Validate Job						Job	Detail Con
8	Backup						. Joh n	ame
	Restore						Descr	intion
	Import						2000	paor
	Export							
	Send and Exit						Last	Modified
	Exit without Send						Mo	odified by
-	Shut down	•	Shut d	own			La	st modified
			Restar	t			Cre	eated by
			Exit to	Windo	NS			
								able long na
								lable iong ha

- 3. From the Menu bar, select File > Shut Down > Exit to Windows.
- 4. Touch **Yes** to confirm.
- 5. On the left Quick access menu, select Scripts to Run.



6. Double-tap RUN-TO-CONFIGURE-TOUCH batch file.

I 📝 📜 👻 Scripts to Run	- C	× נ ~ ?				
$\leftarrow$ $\rightarrow$ $\checkmark$ $\uparrow$ ] > This PC > Documents > Scripts to Run $\checkmark$ $\heartsuit$					) Search Scripts to Run	Q
		Name ^	Date modified	Туре	Size	
<ul> <li>Ż Quick access</li> </ul>			8/31/2022 12·27 PM	Windows Batch File	2 KB	
Desktop	*	IWE-Turn-off	8/24/2022 2:38 PM	Windows Batch File	1 KB	
Downloads	*	LIWE-Turn-on	8/24/2022 2:38 PM	Windows Batch File	1 KB	
Documents	*		0/24/2022 2.30 FW	windows batch the	T KD	
📙 Scripts to Run	*					
🕖 🤝 This PC						
🕨 🕩 Network						



7. Wait for the script to finish. TheTX3 Touch unit will restart.

Administrator: [UWF Configuration]	-	×
Volume state:         Protected           Volume ID:         4b746178-f258-4372-ad75-63a3982565dd		^
File Exclusions: Next Session Exclusions for Volume 4b746178-f258-4372-ad75-63a3982565dd [C:] C:\Program Files (x86)\Mircom Technologies\TX3 Touch\Backup C:\Program Files (x86)\Mircom Technologies\TX3 Touch\Backup C:\Program Files (x86)\Mircom Technologies\TX3 Touch\Database C:\Program Files (x86)\Mircom Technologies\TX3 Touch\Database C:\Users\Admin\AppData\Local\Mircom_Forup_of_Companies C:\Users\Admin\AppData\Local\Mircom_Technologies C:\Program Files (x86)\Mircom Technologies C:\Program Files (x86)\Mircom Technologies C:\Program Files (x86)\Mircom Technologies C:\Program Files (x86)\Mircom Technologies\TX3 Touch\Dags C:\Program Files (x86)\Mircom Technologies\TX3 Touch\Setup files C:\Users\Admin\Dosktop\Calibration\bin\A\Logfiles		
REGISTRY EXCLUSIONS HKEY_LOCAL_MACHINE\SOFTWARE\W0W6d32Node\Mircom\Configuration Tools\TAS-Config HKLM\SOFTWARE\W0W6d32Node\Mircom\Configuration Tools\TAS-Config		
*********************		
* * TX3 TOUCH IS RESTARTING! PLEASE STAND BY* *		
C:\Users\Admin\Documents\Scripts to Run>TIMEOUT /T 5		
Waiting for 5 seconds, press a key to continue		~